

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

April 27, 2005

ZOELLER PUMP CO. ADRIAN FRANCE 3649 CANE RUN RD LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)

Manufacturer: ZOELLER PUMP CO.

Product Name: ZOLLER PRESSURE EFFLUENT FILTER Model Number(s): 5000-0001, 5000-0002 & 5000-0003

Product File No: 20040629

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The sizing calculations of the pressure distribution network must include head loss for this product based on flow rate, model and manufacturer pressure loss chart..

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 04062902.DOC